

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING NO. 7165-1209:191 Page 1 of 1

CATEGORY: Control Unit (Non High-Rise)

LISTEE: System Sensor, 3825 Ohio Avenue, St. Charles, IL 60174
Contact: *Trish Linhart (630) 377-6674 Fax (630) 377-7245

DESIGN: Model PDRP1001 (preaction/deluge); Model PDRP1002 (release). Inherently power-limited; non-coded; local, auxiliary, remote station (protected premises), proprietary (protected premises) and central station service; sprinkler supervisory and releasing device service. Refer to listee's data sheet for system detailed product description and operational considerations. System components:

4XTM	Transmitter Module	4XZM	Relay Module
4XLM	Interface Module	4XMM	Meter Module
DP-4X	Dress Panel	4XARB-1	Main Board
4XARB-2	Main Boards	4XARB-4	Main Board

INSTALLATION: In accordance with listee's printed installation instructions, NFPA 72, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as control panels for use with separately listed compatible initiating and indicating devices.

This control unit does not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to listee's Installation Instructions Manual for details.

XLF: 7165-0028:161

*Rev. 06-16-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**